



Ref: JSWE(B)L/ENV/20-21/023

Date: 11.12.2020

To,

**The Member Secretary
Rajasthan State Pollution Control Board
4-Institutional Area, Jhalana Doongari,
Jaipur – 302004**

Sub: Compliance Report – Consent to Operate Environmental Clearance for 1080 MW Lignite based Power Plant at Village-Bhadresh, District Barmer.

Ref: Consent to Operate

1. Compliance to CTO for Unit 1 & 2, File No. **F(HDF)/Barmer(Barmer)/9(1)/2016-2017/28-30 Order No. 2020-2021/CPM/5618, Dt: 27/04/2020.**
2. Compliance to CTO for Unit 3 & 4, File No. **F(HDF)/Barmer(Barmer)/9(1)/2016-2017/31-33 Order No: 2020-2021/CPM/5619, Dated: 27/04/2020.**
3. Compliance to CTO for Unit 5 & 6, File No. **F(HDF)/Barmer(Barmer)/12(1)/2017-2018/1505-1507; Order No. 2017-2018/HDF/2564, Dt: 30/05/2017.**
4. Compliance to CTO for Unit 7 & 8, File No. **F(HDF)/Barmer(Barmer)/12(1)/2017-2018/1502-1504; Order No. 2017-2018/HDF/2563, Dt: 30/05/2017.**

Dear Sir,

With reference to Consent To Operate issued for Unit # 1-2, 3-4, 5-6 and 7-8 for operating 1080 MW (8 x 135 MW) Lignite Based Thermal Plant of M/s JSW ENERGY (BARMER) Ltd, Dist.- Barmer, Rajasthan, we herewith submit half-yearly compliance report, for the period pertaining to **APRIL– 2020 to SEP – 2020**, for the conditions stipulated in the Environmental clearance issued for this Power Project. Analysis Data has uploaded on JSWEBL website - <http://www.jsw.in/energy/about-barmer-plant>.

We have taken up the Operation activity at the Power Plant as per the conditions stipulated in this Consent to Operate.

Thanking you.

For JSW ENERGY (BARMER) Ltd.

Vinod Jindal

AGM (Operation, Environment & Chemistry)

Enclosure:

1. Compliance Report
2. Stack monitoring Data **_Annexure-I**
3. CEMS Monitoring Data **_Annexure-II**
4. AAQ Monitoring Data **_Annexure-III**
5. Effluent Water Data **_Annexure-IV**
6. STP Treated Water Quality **_Annexure-V**

C.C. The Regional Officer – RSPCB, Balotra.

Compliance to CTO for Unit 1 & 2

File No. F(HDF)/Barmer(Barmer)/9(1)/2016-2017/28-30.

Order No. 2020-2021/CPM/5618, Dt: 27/04/2020.

SN	Condition	Compliance
1	That this Consent to Operate is valid for a period from 01/01/2019 to 31/12/2023	Units are operated during the stipulated period.
2	That this consent is granted for manufacturing / producing following products / by Products or carrying out the following activities or operation/processes or providing following services with capacities of 270 MW.	The 8 x 135 MW lignite based Power project was designed with a total capacity of 1080 MW. As per this Consent, Unit 1 & 2 will be operated to generate 270 MW of power.
3	That this consent to operate is for existing plant, process & capacity and separate consent to establish/operate is required to be taken for any addition/modification/alteration in process or change in capacity or change in fuel	Noted and shall be complied
4	That the quantity of effluent generation and disposal along with mode of disposal for the Treated effluent. a. Domestic 75 KLD b. Industrial 9800 KLD c. Discharge Out Side Premises - NIL	Quantity of waste water generation will not exceed the stipulated. There would be no discharge outside the plant premises. All treated domestic sewage is being used in green belt development.
5	That the sources of air emissions along with pollution control measures and the Emission standards for the prescribed parameters shall be: SO ₂ 600 mg/Nm ³ Particulate Matter 50 mg/Nm ³ NO _x 300 mg/Nm ³ Hg compounds and its 0.03 mg/Nm ³ DG Set (2 x 1000KVA) Acoustic Enclosure NO _x NMHC PM CO	Boiler System is designed with Circulating Fluidised bed Technology – we are adding Lime along with Fuel firing. ESP is designed to comply with Stack Emission standard as stipulated. DG Sets are procured of designed to comply with Environmental Emission standard as stipulated

6	That the domestic sewage shall be treated before disposal so as to conform to the Standards prescribed by the Board as notified under the Environment (protection) Act-1986 for disposal on Land for irrigation. The main parameters for regular monitoring.	Domestic Sewage will be treated and used for green belt development inside the plant area.
7	That the trade effluent shall be treated before disposal so as to conform to the Standards prescribed under the Environment (protection) Act-1986 for disposal into Inland surface water.	The trade effluent is being treated in ETP to comply with the stipulation. Regular monitoring shall be carried out covering the main parameters stipulated.
8	That this consent to operate is valid for power generation of 270 MW capacity with the help of two lignite fired boiler of 440 TPH each.	The 8 x 135 MW lignite based Power project was designed with a total capacity of 1080 MW. As per this Consent, Unit 1 & 2 will be operated to generate 270 MW of power.
9	That the industry shall comply with all the conditions imposed by MoEF, Governments of India vide its office letter no.F.No.J-13011/58/2006-IAII (I) dated 20/07/2007 while issuing EC to your project.	Being complied.
10	That the total capital investment as on 31.03.2018 as per the C. A certificate submitted by the unit is Rs 1623.34 crore which includes the cost of Land, building, plant & machinery and miscellaneous assets only.	Noted.
11	That guidelines on co-processing in cement/ Power/ Steel industries issued by Central Pollution Control Board shall be complied.	Being complied.
12	That the industry shall comply with the emission standards prescribed for Power Plants under the Environment (Protection) Rules, 1986.	Being complied.
13	That the industry shall comply with the emission standards for thermal power plants as notified by MoEF, GoI New Delhi vide gazette notification dated 07/12/2015 and directions issued by Central Pollution Control Board / MOEF from time to time in this regard.	Being Complied.
14	That the industry shall maintain online continuous monitoring system at stack attached to boiler to monitor the emission level of particulate matter(PM),SO ₂ ,NO _x ,Hg along with for effluents and connectivity of the same shall be ensured with RPCB/CPCB server whenever plant is operated.	All these stacks being equipped with Continuous Emission Monitoring Systems (CEMS) and connected to PCB Servers, to ensure the emission of PM, SO ₂ , NO _x to be within prescribed levels.

15	That the industry shall comply with the guidelines of August, 2018 issued by CPCB for "Continuous Emission Monitoring Systems".	Being Complied.
16	That industry shall maintain adequate stack height and acoustic enclosures at the two DG sets of 1000 KVA each capacity.	DG Stack equipped by acoustic enclosure with adequate height.
17	That safe & adequate infrastructure facility in accordance with emission regulation Part-III issued by the Central Pollution Control Board shall be maintained at the stack attached to the boiler & DG Sets for stack emission monitoring.	Being complied.
18	That no other fuel except lignite shall be used in boiler of the power plant without prior permission from the State Board.	Noted shall be complied.
19	That no additional source of air emission shall be installed without prior consent from the State Board.	Noted shall be complied.
20	That all the raw materials (coal etc) shall be stored in closed covered shed and storage facility for coal shall be further strengthened & coal shall not be stored in open areas.	Coal yard equipped with Dust Extraction & suppression Systems at required location and water spray system also equipped to diffuse and suppress any fugitive emissions.
21	That power supply to the production/process shall be interlocked with the pollution control equipment's that in the event of non-functioning of the pollution equipment the production process stops automatically.	CEMS and AQMS connected to PCB server and any non-functioning of equipment's sets off a system alarm and action taken on top priority to rectify the same.
22	That total fresh water requirement from Indira Gandhi Canal shall be 21750KLD(boiler/cooling-21000 KLD+Domestic-150 KLD + Industrial Process-600 KLD) and no ground water shall be abstracted from the ground without prior permission from the Central Ground Water Authority (CGWA).	Being complied.
23	That the industry shall maintain zero discharge status outside the premises. No effluent shall be discharged outside the premises of the industry under any circumstances.	All the effluent will be used inside the plant premises for green belt, road dust suppression and Ash Pond Dust Suppression.
24	That suitable measure for rain water harvesting for artificial recharge of ground water shall be taken.	Rain Water Harvesting is conceptualized in the design of the Plant and a small RH tank is prepared

25	That suitable flow measuring devices/meters on the intake source of water, inlet and outlet of effluent treatment/sewage treatment plant shall be installed and maintained. Daily record of water consumption, effluent generation and its treatment and utilization shall be maintained.	Water is being drawn from IGNP canal - same has metered. Flow meters provided at Outlet of STP and ETP. Water mass balance record maintained on daily basis
26	That the industry shall submit time bound action plan for installation of FGD.	The Project is based on Circulating Fluidized Base Combustion technology for fuel firing and involves injection of lime, which absorbs Sulphur. However space provision has been made for FGD.
27	The domestic effluent shall be treated up to prescribed standards and shall be used for plantation/ green belt development within or outside of the premises.	Treated Domestic Sewage is being treated and used for in house plantation/ green belt development.
28	That the Ministry of Environment and Forest, Govt. of India, Notification dated 14/09/1999 (amended till date) related to the fly ash management, shall be complied and monthly compliance reports shall be submitted to the State Board.	Ash will be utilized as per MOEF guidelines and reported.
29	That the plantation in at least 33% of total area of the plant premises in and around the plant shall be carried out & maintained.	Complied.
30	That the industry shall obtain Environmental Clearance from competent authority under EIA Notification dated 14.09.2016 for any such activity which attracts Environmental Clearance under EIA Notification dated 14.09.2006.	Noted shall be complied
31	That the industry shall comply with the provisions of Hazardous and Other Wastes (Management and Transboundary Movement) Rules, 2016 and record of daily hazardous waste generation and its disposal shall be maintained.	Being Complied
32	That this Consent to Operate shall be subjected to compliance of any direction or order passed by NGT/ Hon'ble Court of law in the matter.	Being complied
33	That the industry shall not use pet coke/furnace oil as fuel in the power plant in compliance to the order dated 24/10/2017 of Hon'ble Supreme Court, wherein ban has been imposed on the use of pet coke and furnace oil in the State of Rajasthan.	Being complied

34	That all the recommendations made in the Charter of Corporate Responsibility for Environment Protection for Thermal power plants shall be implemented.	Being complied
35	That cemented roads shall be provided and maintained inside the premises to minimize the fugitive emissions due to vehicular movements.	RCC roads provided at all required location within the plant to control fugitive emissions.
36	That the industry shall also ensure the compliance of all the conditions of consent order no. 2016-2017/HDF/2505 dt 03.01.2017.	Being Complied
37	That the industry shall submit the half yearly compliance report of all the above conditions to the State Board.	Noted shall be complied.
38	That, notwithstanding anything provided hereinabove, the State Board shall have power and reserves its right, as contained under section 27(2) of the Water Act and under section 21(6) of the Air Act to review anyone or all the conditions imposed here in above and to make such variation as it deemed fit for the purpose of Air Act & Water Act.	Being complied
39	That the grant of this Consent to Operate is issued from the environmental angle only, and does not absolve the project proponent from the other statutory obligations prescribed under any other law or any other instrument in force. The sole and complete responsibility to comply with the conditions laid down in all other laws for the time-being in force, rests with the industry/ unit/ project proponent.	Noted shall be complied
40	That the grant of this Consent to Operate shall not, in any way, adversely affect or jeopardize the legal proceeding, if any, instituted in the past or that could be instituted against you by the State Board for violation of the provisions of the Act or the Rules made thereunder.	Being complied

Compliance to CTO for Unit 3 & 4

File No. F(HDF)/Barmer(Barmer)/9(1)/2016-2017/31-33

Order No: 2020-2021/CPM/5619, Dated: 27/04/2020

SN	Condition	Compliance
1	That this Consent to Operate is valid for a period from 01/12/2018 to 30/11/2023	Units are operated during the stipulated period.
2	That this consent is granted for manufacturing / producing following products / by Products or carrying out the following activities or operation/processes or providing following services with capacities of 270 MW.	The 8 x 135 MW lignite based Power project was designed with a total capacity of 1080 MW. As per this Consent, Unit 3 & 4 will be operated to generate 270 MW of power.
3	That this consent to operate is for existing plant, process & capacity and separate consent to establish/operate is required to be taken for any addition/modification/alteration in process or change in capacity or change in fuel	Noted and shall be complied
4	That the quantity of effluent generation and disposal along with mode of disposal for the Treated effluent. a. Domestic 75 KLD b. Industrial 9800 KLD c. Discharge Out Side Premises - NIL	Quantity of waste water generation will not exceed the stipulated. There would be no discharge outside the plant premises. All treated domestic sewage is being used in green belt development.
5	That the sources of air emissions along with pollution control measures and the Emission standards for the prescribed parameters shall be: SO ₂ 600 mg/Nm ³ Particulate Matter 50 mg/Nm ³ NO _x 300 mg/Nm ³ Hg compounds and its 0.03 mg/Nm ³ DG Set (2 x 1000KVA) Acoustic Enclosure NO _x NMHC PM CO	Boiler System is designed with Circulating Fluidised bed Technology – we are adding Lime along with Fuel firing. ESP is designed to comply with Stack Emission standard as stipulated. DG Sets are procured of designed to comply with Environmental Emission standard as stipulated

6	That the Stage II (Unit- III & IV) plant will comply with the standards as prescribed vide MOEF notification no GSR 826(E) dated 16 th November, 2009 with respect to national Ambient Air Quality Standards.	Being complied.
7	That the domestic sewage shall be treated before disposal so as to conform to the Standards prescribed by the Board as notified under the Environment (protection) Act-1986 for disposal on Land for irrigation. The main parameters for regular monitoring.	Domestic Sewage will be treated and used for green belt development inside the plant area.
8	That the trade effluent shall be treated before disposal so as to conform to the Standards prescribed under the Environment (protection) Act-1986 for disposal into Inland surface water.	The trade effluent is being treated in ETP to comply with the stipulation. Regular monitoring shall be carried out covering the main parameters stipulated.
9	That this consent to operate is valid for power generation of 270 MW capacity with the help of two lignite fired boiler of 440 TPH each.	The 8 x 135 MW lignite based Power project was designed with a total capacity of 1080 MW. As per this Consent, Unit 1 & 2 will be operated to generate 270 MW of power.
10	That the industry shall comply with all the conditions imposed by MoEF, Governments of India vide its office letter no.F.No.J-13011/58/2006-IAII (I) dated 20/07/2007 while issuing EC to your project.	Being complied.
11	That the total capital investment as on 31.03.2018 as per the C. A certificate submitted by the unit is Rs 1352.79 crore which includes the cost of Land, building, plant & machinery and miscellaneous assets only.	Noted.
12	That guidelines on co-processing in cement/ Power/ Steel industries issued by Central Pollution Control Board shall be complied.	Noted - Shall be complied.
13	That the industry shall comply with the emission standards prescribed for Power Plants under the Environment (Protection) Rules, 1986.	Being complied.
14	That the industry shall comply with the emission standards for thermal power plants as notified by MoEF, GoI New Delhi vide gazette notification dated 07/12/2015 and directions issued by Central Pollution Control Board / MOEF from time to time in this regard.	Being Complied.

15	That the industry shall maintain online continuous monitoring system at stack attached to boiler to monitor the emission level of particulate matter(PM),SO ₂ ,NO _x ,Hg along with for effluents and connectivity of the same shall be ensured with RPCB/CPCB server whenever plant is operated.	All these stacks being equipped with Continuous Emission Monitoring Systems (CEMS) and connected to PCB Servers, to ensure the emission of PM, SO ₂ , NO _x to be within prescribed levels.
16	That the industry shall comply with the guidelines of August, 2018 issued by CPCB for "Continuous Emission Monitoring Systems".	Being Complied.
17	That industry shall maintain adequate stack height and acoustic enclosures at the two DG sets of 1000 KVA each capacity.	DG Stack equipped by acoustic enclosure with adequate height.
18	That safe & adequate infrastructure facility in accordance with emission regulation Part-III issued by the Central Pollution Control Board shall be maintained at the stack attached to the boiler & DG Sets for stack emission monitoring.	Being complied.
19	That no other fuel except lignite shall be used in boiler of the power plant without prior permission from the State Board.	Noted shell be complied.
20	That no additional source of air emission shall be installed without prior consent from the State Board.	Noted shell be complied.
21	That all the raw materials (coal etc.) shall be stored in closed covered shed and storage facility for coal shall be further strengthened & coal shall not be stored in open areas.	Coal yard equipped with Dust Extraction & suppression Systems at required location and water spray system also equipped to diffuse and suppress any fugitive emissions.
22	That power supply to the production/process shall be interlocked with the pollution control equipment's that in the event of non-functioning of the pollution equipment the production process stops automatically.	CEMS and AQMS connected to PCB server and any non-functioning of equipment's sets off a system alarm and action taken on top priority to rectify the same.
23	That total fresh water requirement from Indira Gandhi Canal shall be 21750KLD(boiler/cooling-21000 KLD+Domestic-150 KLD + Industrial Process-600 KLD) and no ground water shall be abstracted from the ground without prior permission from the Central Ground Water Authority (CGWA).	Being complied.
24	That the industry shall maintain zero discharge status outside the premises. No effluent shall be discharged outside the premises of the industry under any circumstances.	All the effluent will be used inside the plant premises for green belt, road dust suppression and Ash Pond Dust Suppression.

25	That suitable measure for rain water harvesting for artificial recharge of ground water shall be taken.	Rain Water Harvesting is conceptualized in the design of the Plant and a small RH tank is prepared
26	That suitable flow measuring devices/meters on the intake source of water, inlet and outlet of effluent treatment/sewage treatment plant shall be installed and maintained. Daily record of water consumption, effluent generation and its treatment and utilization shall be maintained.	Water is being drawn from IGNP canal - same has metered. Flow meters provided at Outlet of STP and ETP. Water mass balance record maintained on daily basis
27	That the industry shall submit time bound action plan for installation of FGD.	The Project is based on Circulating Fluidized Base Combustion technology for fuel firing and involves injection of lime, which absorbs Sulphur. However space provision has been made for FGD.
28	The domestic effluent shall be treated up to prescribed standards and shall be used for plantation/ green belt development within or outside of the premises.	Treated Domestic Sewage is being treated and used for in house plantation/ green belt development.
29	That the Ministry of Environment and Forest, Govt. of India, Notification dated 14/09/1999 (amended till date) related to the fly ash management, shall be complied and monthly compliance reports shall be submitted to the State Board.	Ash will be utilized as per MOEF guidelines and reported.
30	That the plantation in at least 33% of total area of the plant premises in and around the plant shall be carried out & maintained.	Complied.
31	That the industry shall obtain Environmental Clearance from competent authority under EIA Notification dated 14.09.2016 for any such activity which attracts Environmental Clearance under EIA Notification dated 14.09.2006.	Noted shall be complied
32	That the industry shall comply with the provisions of Hazardous and Other Wastes (Management and Transboundary Movement) Rules, 2016 and record of daily hazardous waste generation and its disposal shall be maintained.	Being Complied
33	That this Consent to Operate shall be subjected to compliance of any direction or order passed by NGT/ Hon'ble Court of law in the matter.	Being complied

34	That the industry shall not use pet coke/furnace oil as fuel in the power plant in compliance to the order dated 24/10/2017 of Hon'ble Supreme Court, wherein ban has been imposed on the use of pet coke and furnace oil in the State of Rajasthan.	Being complied
35	That all the recommendations made in the Charter of Corporate Responsibility for Environment Protection for Thermal power plants shall be implemented.	Being complied
36	That cemented roads shall be provided and maintained inside the premises to minimize the fugitive emissions due to vehicular movements.	RCC roads provided at all required location within the plant to control fugitive emissions.
37	That the industry shall also ensure the compliance of all the conditions of consent order no. 2016-2017/HDF/2506 dt 04.01.2017.	Being Complied
38	That the industry shall submit the half yearly compliance report of all the above conditions to the State Board.	Being complied.
39	That, notwithstanding anything provided hereinabove, the State Board shall have power and reserves its right, as contained under section 27(2) of the Water Act and under section 21(6) of the Air Act to review anyone or all the conditions imposed here in above and to make such variation as it deemed fit for the purpose of Air Act & Water Act.	Being complied
40	That the grant of this Consent to Operate is issued from the environmental angle only, and does not absolve the project proponent from the other statutory obligations prescribed under any other law or any other instrument in force. The sole and complete responsibility to comply with the conditions laid down in all other laws for the time-being in force, rests with the industry/ unit/ project proponent.	Noted shall be complied
41	That the grant of this Consent to Operate shall not, in any way, adversely affect or jeopardize the legal proceeding, if any, instituted in the past or that could be instituted against you by the State Board for violation of the provisions of the Act or the Rules made thereunder.	Being complied

Compliance to CTO for Unit 5 & 6

File No. F(HDF)/Barmer(Barmer)/12(1)/2017-2018/1505-1507

Order No. 2017-2018/HDF/2564, Dt: 30/05/2017

SN	Condition	Compliance
1	That this Consent to Operate is valid for a period from 01/11/2016 to 31/10/2021	Units are operated during the stipulated period.
2	That this consent is granted for manufacturing / producing following products / by Products or carrying out the following activities or operation/processes or providing following services with capacities of 270 MW.	The 8 x 135 MW lignite based Power project was designed with a total capacity of 1080 MW. As per this Consent, Unit 5 & 6 only will be operated to generate 270 MW of power.
3	That this consent to operate is for existing plant, process & capacity and separate consent to establish/operate is required to be taken for any addition/modification/alteration in process or change in capacity or change in fuel	Noted and shall be complied
4	That the quantity of effluent generation and disposal along with mode of disposal for the Treated effluent. a. Domestic 75 KLD b. Industrial 9800 KLD c. Discharge Out Side Premises - NIL	Quantity of waste water generation will not exceed the stipulated. There would be no discharge outside the plant premises. All treated domestic sewage is being used in green belt development.
5	That the sources of air emissions along with pollution control measures and the Emission standards for the prescribed parameters shall be: Boiler V: ESP: 100 mg/Nm ³ Boiler VI: ESP: 100 mg/Nm ³ DG Set (1000 KVA)	ESP is designed to comply with Stack Emission standard as stipulated.
6	That the stage III (Unit V & VI) plant will comply with the standards as prescribed vide MOEF notification No. GSR 826(E) dated 16 th November 2009 with respect to National Ambient Air Quality Standards.	Being Complied.

7	That the domestic sewage shall be treated before disposal so as to conform to the Standards prescribed by the Board as notified under the Environment (protection) Act-1986 for disposal on Land for irrigation. The main parameters for regular monitoring.	Domestic Sewage will be treated and used for green belt development irrigation.
8	That the trade effluent shall be treated before disposal so as to conform to the Standards prescribed under the Environment (protection) Act-1986 for disposal into Inland surface water.	The trade effluent is being treated in ETP to comply with the stipulation. Regular monitoring shall be carried out covering the main parameters stipulated.
9	That this consent to operate is being issued for production capacity of 2 x 135 MW (Unit 5 & 6) thermal plant	Noted – Being Complied.
10	That the total Project cost of the unit shall not exceed 1464.40 crores including cost of land, building, plant and machinery.	Noted – Being Complied for Unit 5 & 6.
11	That the industry shall comply with all the conditions imposed by MoEF, Governments of India vide its office letter no.F.No.J-13011/58/2006-IA(I)dated20/07/2007 while issuing EC to your project.	Being complied.
12	That all the conditions imposed vide letter no. F-Tech/Barmer (Barmer)/3(1)2008-2009/ 4403-4407 dated 20/09/2011 shall be complied.	Being Complied.
13	That the charter of Corporate Responsibility for Environment Protection specified for power plants shall be complied	Being Complied.
14	That the Industry will comply with the standards as prescribed vide MOEF notification No. GSR 826(E) dated 16 th November 2009 with respect to National Ambient Air Quality Standards.	Being Complied.
15	That the industry shall provide & maintain adequate dust collection and Extraction system to control fugitive dust emission at coal crusher and coal Transfer points and coal handling and storage areas.	Dust Extraction & suppression Systems have been implemented at required location in lignite handling location. And road coal dust collector (mobile) unit is engaged at coal yard and nearby area to collect the same.
16	That the particulate emissions from stack of various sections of power plant shall Not exceed 100 mg/NM3 and continuous online arrangement for stack monitoring Of particular emissions shall be provided.	ESP is designed to comply with Stack Emission standard as stipulated with continuous emission monitoring system is being installed for the monitoring of flue emissions.

17	That the industry shall maintain opacity meter with each boiler stack to monitor the emission level of particulate matter. The monthly observation will be submitted to R.O. Office along with the reason / clarification for any recorded violation of the prescribed standards.	Being Complied.
18	The Low NOx burners shall be installed at boiler feeding system.	Boiler system is designed on CFBC Technology in which lime is added to furnace for adsorb SOx and NOx generated during combustion of fuel.
19	That the level of SPM within distance 3 -10 M from dust generating source/plant Shall not exceed to 600 mg/NM3 in ambient air.	Necessary measures shall be taken to comply with the stipulation. All the locations are under monitoring.
20	That for the control fugitive emission guidelines / code of practice as issued by CPCB will be followed.	Necessary measures shall be taken to comply with the stipulation.
21	That the project proponent shall undertake measures and ensure that no fugitive fly ash emissions take place at any point of time.	Necessary measures shall be taken to comply with the stipulation.
22	That Fly ash shall be collected in dry form and 100 % utilising shall be ensured by 28.02.2013. Ash to be disposed off in the pond shall be through HCSD system.	Fly ash is being collected in dry form from the operational two Units and is being lifted by Cement Plants. Unutilized ash, if any, would be disposed off to the emergency ash pond through HCSD system.
23	That no industrial effluent will be discharged from the factory premises in to a Stream or well or sewer or land and the effluent generated from captive power Plant shall be used for ash quenching.	All the effluent will be used inside the plant premises for green belt, road dust suppression and Ash Pond Dust Suppression.
24	That the industrial effluent generated from R.O. rejects, DM plant & cooling Tower shall be neutralized & will be used for cooling proposes after taking it into Water circulation tank. No industrial effluent will be discharged inside or outside The factory premises.	That the industrial effluent generated from D.M. rejects & cooling Tower is being used for cooling proposes after taking it into Water circulation tank.
25	The domestic effluent shall be treated up to prescribed standards and shall be Used for plantation/green belt development within the premises.	Domestic Sewage will be treated and using for in house plantation/ green belt development.

26	Ash pond shall be lined with HDPE/LDPE lining or any suitable impermeable media such that no leachate takes place at any point of time. Adequate safety measures shall also be implemented to protect the ash dyke from getting breached.	The ash pond is lined at the bottom with 0.5 mm thick HDPE geo-membrane, to avoid any leachate to the ground.
27	That no ground water shall be abstracted without prior permission from the State Board and Central Ground Water Authority.	Being complied.
28	That suitable flow measuring devices/meters on the intake source of water, inlet and outlet effluent treatment / sewage treatment plant shall be installed and Maintained. Daily record of water consumption, effluent generation and its Treatment and utilization shall be maintained.	Being Complied.
29	That suitable measure for rain water harvesting for artificial recharge of ground Water shall be taken.	Rain Water Harvesting is conceptualized in the design of the Plant and a small RH tank is prepared
30	The industry shall comply with the MoEF, Government of India, Notification date 14th September 1999 with till the date amendments relating to fly ash Management and shall provide relevant details to the state Board, MoEF, Government of India.	Ash will be utilized as per MOEF guidelines and reported.
31	That, notwithstanding anything provided hereinabove, the state board shall have power and reserves the right, as contained under section 27(2) of the water Act and under section 21(6) of the Air Act to review anyone or all the conditions imposed here in above and to make such variation as it deemed fit for the purpose of air act & water act	Being Complied
32	That the grant of this consent to operate is issued from the environmental angle only, and does not above absolve the project proponent from the other statutory obligations prescribed under any other law or any other instrument in force. The sole and complete responsibility to comply with the conditions laid down in all other laws for the time-being in force, rests with the industry/unit/project proponent.	Being Complied
33	That the grant of the this consent to operate shall not, in any way, adversely affect or jeopardize the legal proceeding, if any, instituted in the past or that could be instituted against you by the state board for violation of the provision of the act or rules made thereunder	Being Complied

Compliance to CTO for Unit 7 & 8

File No. F(HDF)/Barmer(Barmer)/12(1)/2017-2018/1502-1504

Order No. 2017-2018/HDF/2563, Dt: 30/05/2017

SN	Condition	Compliance
1	That this Consent to Operate is valid for a period from 01/11/2016 to 31/10/2021	Units are operated during the stipulated period.
2	That this consent is granted for manufacturing / producing following products / by Products or carrying out the following activities or operation/processes or providing following services with capacities of 270 MW.	The 8 x 135 MW lignite based Power project was designed with a total capacity of 1080 MW. As per this Consent, Unit 5 & 6 only will be operated to generate 270 MW of power.
3	That this consent to operate is for existing plant, process & capacity and separate consent to establish/operate is required to be taken for any addition/modification/alteration in process or change in capacity or change in fuel	Noted and shall be complied
4	That the quantity of effluent generation and disposal along with mode of disposal for the Treated effluent. a. Domestic 75 KLD b. Industrial 9800 KLD c. Discharge Out Side Premises - NIL	Quantity of waste water generation will not exceed the stipulated. There would be no discharge outside the plant premises. All treated domestic sewage is being used in green belt development.
5	That the sources of air emissions along with pollution control measures and the Emission standards for the prescribed parameters shall be: Boiler VII: ESP: 100 mg/Nm ³ Boiler VIII: ESP : 100 mg/Nm ³	ESP is designed to comply with Stack Emission standard as stipulated.
6	That the stage IV (Unit VII & VIII) plant will comply with the standards as prescribed vide MOEF notification No. GSR 826(E) dated 16 th November 2009 with respect to National Ambient Air Quality Standards.	Being Complied.

7	That the domestic sewage shall be treated before disposal so as to conform to the Standards prescribed by the Board as notified under the Environment (protection) Act-1986 for disposal into Inland Surface Water. The main parameters for regular monitoring.	Domestic Sewage will be treated and used for green belt development irrigation.
8	That the trade effluent shall be treated before disposal so as to conform to the Standards prescribed under the Environment (protection) Act-1986 for disposal into Inland surface water.	The trade effluent is being treated in ETP to comply with the stipulation. Regular monitoring shall be carried out covering the main parameters stipulated.
9	That this consent to operate is being issued for production capacity of 2 x 135 MW (Unit 7 & 8) thermal plant	Noted – Being Complied.
10	That the total Project cost of the unit shall not exceed 1297.5 crores including cost of land, building, plant and machinery.	Noted – Being Complied.
11	That the industry shall comply with all the conditions imposed by MoEF, Governments of India vide its office letter no.F.No.J-13011/58/2006-IA(I)dated20/07/2007 while issuing EC to your project.	Being complied.
12	That all the conditions imposed vide letter no. F-Tech/Barmer (Barmer)/3(1)2008-2009/2487-2489 dated 04/07/2011 shall be complied.	Being Complied.
13	That the Charter of Corporate Responsibility for Environment Protection specified for power plants shall be complied	Being Complied.
14	That the Industry will comply with the standards as prescribed vide MOEF notification No. GSR 826(E) dated 16 th November 2009 with respect to National Ambient Air Quality Standards.	Being Complied.
15	That the industry shall provide & maintain adequate dust collection and Extraction system to control fugitive dust emission at coal crusher and coal Transfer points and coal handling and storage areas.	Dust Extraction & suppression Systems have been implemented at required location in lignite handling location. And road coal dust collector (mobile) unit is engaged at coal yard and nearby area to collect the same.

16	That the particulate emissions from stack of various sections of power plant shall Not exceed 100 mg/NM3 and continuous online arrangement for stack monitoring Of particular emissions shall be provided.	ESP is designed to comply with Stack Emission standard as stipulated with continuous emission monitoring system is being installed for the monitoring of flue emissions.
17	That the industry shall maintain opacity meter with each boiler stack to monitor the emission level of particulate matter. The monthly observation will be submitted to R.O. Office along with the reason / clarification for any recorded violation of the prescribed standards.	Being Complied.
18	The Low NOx burners shall be installed at boiler feeding system.	Boiler system is designed on CFBC Technology in which lime is added to furnace for adsorb SOx and NOx generated during combustion of fuel.
19	That the level of SPM within distance 3 -10 M from dust generating source/plant Shall not exceed to 600 mg/NM3 in ambient air.	Necessary measures shall be taken to comply with the stipulation. All the locations are under monitoring.
20	That the project proponent shall undertake measures and ensure that no fugitive fly ash emissions take place at any point of time.	Necessary measures shall be taken to comply with the stipulation.
21	That for the control fugitive emission guidelines / code of practice as issued by CPCB will be followed.	Necessary measures shall be taken to comply with the stipulation.
22	That no industrials effluent will be discharged from the factory premises in to a Stream or well or sewer or land and the effluent generated from captive power Plant shall be used for ash quenching.	All the effluent will be used inside the plant premises for green belt, road dust suppression and Ash Pond Dust Suppression.
23	That the industrial effluent generated from R.O. rejects, DM plant & cooling Tower shall be neutralized & will be used for cooling proposes after taking it into Water circulation tank. No industrial effluent will be discharged inside or outside The factory premises.	That the industrial effluent generated from D.M. rejects & cooling Tower is being used for cooling proposes after taking it into Water circulation tank.
24	The domestic effluent shall be treated up to prescribed standards and shall be Used for plantation/green belt development within the premises.	Domestic Sewage will be treated and using for in house plantation/ green belt development.
25	That no ground water shall be abstracted without prior permission from the State Board and Central Ground Water Authority.	Being complied.

26	That suitable flow measuring devices/meters on the intake source of water, inlet and outlet effluent treatment / sewage treatment plant shall be installed and Maintained. Daily record of water consumption, effluent generation and its Treatment and utilization shall be maintained.	Shall be complied with.
27	That suitable measure for rain water harvesting for artificial recharge of ground Water shall be taken.	Rain Water Harvesting is conceptualized in the design of the Plant and a small RH tank is prepared
28	The industry shall comply with the MoEF, Government of India, Notification date 14th September 1999 with till the date amendments relating to fly ash Management and shall provide relevant details to the state Board, MoEF, Government of India.	Ash will be utilized as per MOEF guidelines and reported.
29	That, notwithstanding anything provided hereinabove, the state board shall have power and reserves the right, as contained under section 27(2) of the water Act and under section 21(6) of the Air Act to review anyone or all the conditions imposed here in above and to make such variation as it deemed fit for the purpose of air act & water act	Being Complied
30	That the grant of this consent to operate is issued from the environmental angle only, and does not above absolve the project proponent from the other statutory obligations prescribed under any other law or any other instrument in force. The sole and complete responsibility to comply with the conditions laid down in all other laws for the time-being in force, rests with the industry/unit/project proponent.	Being Complied
31	That the grant of the this consent to operate shall not, in any way, adversely affect or jeopardize the legal proceeding, if any, instituted in the past or that could be instituted against you by the state board for violation of the provision of the act or rules made thereunder	Being Complied

Compliance Status of Thermal Plant – Charter on Corporate Responsibility for Environmental Protection

Sr. No.	CREP points for Thermal Plant	Compliance status
1	Implementation of Environmental Standards (emission & effluent) in non-compliant* Power Plants (31 & 27)	Project come up in 2006 – Not Applicable
	- Submission of action plan June 30, 2003	
	- Placement of order for Pollution of control equipment September, 2003	
	- Installation & commission December -31, 2005	
2	For existing thermal power plants, a feasibility study will be carried out by Central Electricity Authority (CEA) to examine possibility to reduce the particulate matter emissions to 100 mg/Nm ³ . The studies shall also suggest the road map to meet 100 mg/Nm ³ . The studies shall also suggest the road map to meet 100 mg/Nm ³ wherever found feasible. CEA shall submit the report by March 2004.	Project come up in 2006 – Project is designed for the particulate matter emissions to 100 mg/Nm ³ . MOEF has also stipulated in EC conditions.
3	New / expansion power projects to be accorded environmental clearance on or after 1.4.1.2003 shall meet the limit of 100 mg/Nm ³ for particulate matter.	Complied
4	Development of SO ₂ & NO _x emission standards for coal based plants by December 2003.	Complied as per EC conditions by MOEF & CFE & CTO conditions by RSPCB
	- New/ expansion power projects shall meet the limit of SO ₂ & NO _x w.e.f. 1.1.2005.	
	- Existing power plants shall meet the limit of SO ₂ & NO _x w.e.f. 1.1.2006.	
5	Install/activate opacity meters/ continuous monitoring system in all the units by December 31, 2004 with proper calibration system.	All Eight flue has provided with CEMS system with Opacity meter
6	Development of guidelines/ standards for mercury and other toxic heavy metals emissions by December 2003.	The project is Lignite Coal Based Pit head project and EC, CTO and CFE Conditions being complied.
		Both are well below the norms
7	Review of stack height requirement and guidelines for power plants based on micro meteorological data by June 2003.	Stack height has been designed as per Micro Meteorological conditions and condition of EC granted by MOEF.
8	Implementation of use of beneficiated coal as per GOI Notification:	Not Applicable
	Power plants will sign fuel supply agreement (FSA)	– Project is pit head project and

	Options/mechanism for setting up of coal washeries as a long term measure	designed on basis of Lignite coal from Adjacent Kapurdi and Jalipa Lignite.
	* Coal India will up its own washery	
	* State Electricity Board to set up its own washery	
	* Coal India to ask private entrepreneurs to set up washeries for CIL and taking washing charges	
	* SEBs to select a private entrepreneur to set up a washery near pit-head installation of coal beneficiation plant	
9	Power plants will indicate their requirement of abandoned coal mines for ash disposal & Coal India/ MOC shall provide the list of abandoned mines by June 2003 to CEA.	Complied
10	Power plants will provide dry ash to the users outside the premises or uninterrupted access to the users within six months.	This is in practice – Complied
11	Power Plants should provide dry fly ash free of cost to the users.	This is in practice – Complied
12	State P.W.Ds/ construction & development agencies shall also adhere to the specifications/Schedules of CPWD for ash based products utilization MoEF will take up the matter with State Governments.	
13	(i) New plants to be accorded environmental 1.04.2003 shall adopt dry fly ash extraction or dry disposal system or Medium (35-40%) ash concentration slurry disposal system or Lean phase with hundred percent ash water re-circulation system depending upon site specific environmental situation.	Dry Fly ash Handling system is incorporated for better utilisation of Ash.
	(ii) Existing plants shall adopt any of the systems mentioned in 13 (i) by December 2004.	Not applicable
14	Fly ash Mission shall prepare guidelines/manuals for fly ash utilization by March 2004.	Currently Cement Manufacturing Industries and Brick manufactures are lifting up Ash.
15	New plants shall promote adoption of clean coal and clean power generation technologies	Project is pit head project and designed on basis of Lignite coal from Adjacent Kapurdi and Jalipa Lignite.

ANNEXURE-I

STACK EMISSION MONITORING RESULTS APR – 2020 to MAR – 2020

Month: Apr, 2020

SN	Parameters	UOM	Unit-I	Unit-II	Unit-III	Unit-IV	Unit-V	Unit-VI	Unit-VII	Unit-VIII
1	Average Velocity	m/Sec	16.2	16.0	16.5	18.4	14.9	15.6	17.6	16.4
2	Flow	Nm ³ /Sec	133	128	130	147	125	129	141	133
3	Stack Exit Temp.	°C	132	137	148	153	123	124	132	142
4	Particulate Matter	mg/Nm ³	72	52	57	67	48	75	58	61
5	Sulphur Dioxide	mg/Nm ³	462	435	453	422	460	461	408	437
6	Oxides of Nitrogen	mg/Nm ³	96	102	93	63	142	87	81	92

Month: May, 2020

SN	Parameters	UOM	Unit-I	Unit-II	Unit-III	Unit-IV	Unit-V	Unit-VI	Unit-VII	Unit-VIII
1	Average Velocity	m/Sec	16.7	15.8	16.2	17.9	13.2	15.9	16.9	16.1
2	Flow	Nm ³ /Sec	136	130	131	148	126	128	141	133
3	Stack Exit Temp.	°C	134	138	149	152	123	125	133	145
4	Particulate Matter	mg/Nm ³	47.2	52	48.1	43.1	52.1	49.2	47.5	54.9
5	Sulphur Dioxide	mg/Nm ³	355	516	521	495	361	384	492	475
6	Oxides of Nitrogen	mg/Nm ³	143	154	185	211	159	158	179	155

Month: Jun, 2020

SN	Parameters	UOM	Unit-I	Unit-II	Unit-III	Unit-IV	Unit-V	Unit-VI	Unit-VII	Unit-VIII
1	Average Velocity	m/Sec	16.5	15.2	17.6	16.2	13.7	15.6	16.4	15.6
2	Flow	Nm ³ /Sec	136	130	133	149	128	130	143	135
3	Stack Exit Temp.	°C	138	137	154	155	126	127	136	145
4	Particulate Matter	mg/Nm ³	48.2	51.2	47.3	46.3	49.8	48.2	46.4	52.4
5	Sulphur Dioxide	mg/Nm ³	362	524	518	483	365	386	484	470
6	Oxides of Nitrogen	mg/Nm ³	143	151	181	224	161	163	176	158

ANNEXURE-I
Month: Jul' 2020

SN	Parameters	UOM	Unit-I	Unit-II	Unit-III	Unit-IV	Unit-V	Unit-VI	Unit-VII	Unit-VIII
1	Average Velocity	m/Sec	17.8	17.9	18.2	17.7	17.2	17.9	17.4	17.8
2	Flow	Nm ³ /Sec	134	133	134	149	139	138	139	139
3	Stack Exit Temp.	°C	137	139	158	155	130	130	136	147
4	Particulate Matter	mg/Nm ³	48	51	52	48	50	49	48	50
5	Sulphur Dioxide	mg/Nm ³	458	485	429	489	471	491	484	478
6	Oxides of Nitrogen	mg/Nm ³	182	193	191	192	185	194	189	188

Month: Aug' 2020

SN	Parameters	UOM	Unit-I	Unit-II	Unit-III	Unit-IV	Unit-V	Unit-VI	Unit-VII	Unit-VIII
1	Average Velocity	m/Sec	17.4	17.3	17.4	17.2	17.3	17.9	17.0	17.1
2	Flow	Nm ³ /Sec	133	132	132	133	135	136	138	136
3	Stack Exit Temp.	°C	138	137	152	151	127	128	131	142
4	Particulate Matter	mg/Nm ³	44	47	47	43	46	41	45	46
5	Sulphur Dioxide	mg/Nm ³	441	476	418	481	461	464	479	465
6	Oxides of Nitrogen	mg/Nm ³	172	179	182	181	174	176	180	169

Month: Sep' 2020

SN	Parameters	UOM	Unit-I	Unit-II	Unit-III	Unit-IV	Unit-V	Unit-VI	Unit-VII	Unit-VIII
1	Average Velocity	m/Sec	17.5	17.8	17.1	17.4	17.4	17.7	17.4	17.0
2	Flow	Nm ³ /Sec	135	133	132	132	134	136	137	136
3	Stack Exit Temp.	°C	140	138	152	149	127	129	133	142
4	Particulate Matter	mg/Nm ³	42.8	45.7	47	43	46	43.2	44	45
5	Sulphur Dioxide	mg/Nm ³	449	479	418	478	462	463	480	463
6	Oxides of Nitrogen	mg/Nm ³	184	175	182	183	175	178	172	172

ANNEXURE-II

Unit # 1 - Continuous Emission Monitoring System-CEMS DATA

Unit # 1 - Continuous Emission Monitoring System-CEMS DATA

Month		SOX mg/m3	NOX mg/m3	SPM mg/m3
Apr-20	Average	254	39	69
	Max	438	164	71
May-20	Average	359	111	67
	Max	456	163	76
Jun-20	Average	412	146	68
	Max	454	173	75
Jul-20	Average	212	97	53
	Max	428	158	75
Aug-20	Average	292	114	53
	Max	440	210	71
Sep-20	Average	252	113	56
	Max	412	170	72

Unit # 2 - Continuous Emission Monitoring System-CEMS DATA

Month		SOX mg/m3	NOX mg/m3	SPM mg/m3
Apr-20	Average	303	168	43
	Max	415	227	48
May-20	Average	321	162	38
	Max	425	219	50
Jun-20	Average	377	176	51
	Max	460	203	69
Jul-20	Average	424	188	49
	Max	446	217	56
Aug-20	Average	369	197	29
	Max	452	221	95
Sep-20	Average	390	204	43
	Max	425	230	75

Unit # 3 - Continuous Emission Monitoring System-CEMS DATA

Month		SOX mg/m3	NOX mg/m3	SPM mg/m3
Apr-20	Average	416	168	71
	Max	464	227	75
May-20	Average	404	162	70
	Max	483	219	76
Jun-20	Average	412	176	74
	Max	438	203	76
Jul-20	Average	419	188	69
	Max	452	217	75
Aug-20	Average	423	197	64
	Max	466	221	72
Sep-20	Average	395	204	66
	Max	431	230	76

Unit # 4 - Continuous Emission Monitoring System-CEMS DATA

Month		SOX mg/m3	NOX mg/m3	SPM mg/m3
Apr-20	Average	303	117	43
	Max	456	154	68
May-20	Average	427	147	49
	Max	458	189	81
Jun-20	Average	399	157	41
	Max	443	202	96
Jul-20	Average	383	118	33
	Max	458	184	45
Aug-20	Average	375	140	45
	Max	440	182	86
Sep-20	Average	391	154	48
	Max	446	208	60

Unit # 5 - Continuous Emission Monitoring System-CEMS DATA

Month		SOX mg/m3	NOX mg/m3	SPM mg/m3
Apr-20	Average	422	97	50
	Max	465	141	57
May-20	Average	381	101	59
	Max	464	179	71
Jun-20	Average	365	104	56
	Max	415	171	63
Jul-20	Average	345	118	43
	Max	463	237	56
Aug-20	Average	360	143	43
	Max	465	232	74
Sep-20	Average	389	172	38
	Max	446	256	48

Unit # 6 - Continuous Emission Monitoring System-CEMS DATA

Month		SOX mg/m3	NOX mg/m3	SPM mg/m3
Apr-20	Average	253	115	42
	Max	461	149	61
May-20	Average	399	110	67
	Max	457	255	77
Jun-20	Average	362	78	47
	Max	425	249	58
Jul-20	Average	375	152	48
	Max	449	237	59
Aug-20	Average	354	138	39
	Max	452	202	65
Sep-20	Average	417	160	43
	Max	460	210	49

Unit # 7 - Continuous Emission Monitoring System-CEMS DATA

Month		SOX mg/m3	NOX mg/m3	SPM mg/m3
Apr-20	Average	275	78	53
	Max	422	98	58
May-20	Average	287	104	61
	Max	439	192	63
Jun-20	Average	348	86	63
	Max	443	181	72
Jul-20	Average	425	77	62
	Max	466	164	73
Aug-20	Average	369	97	59
	Max	456	167	75
Sep-20	Average	366	100	62
	Max	425	151	75

Unit # 8 - Continuous Emission Monitoring System-CEMS DATA

Month		SOX mg/m3	NOX mg/m3	SPM mg/m3
Apr-20	Average	310	104	41
	Max	435	149	52
May-20	Average	399	125	52
	Max	455	198	55
Jun-20	Average	350	113	56
	Max	443	196	60
Jul-20	Average	407	147	55
	Max	453	232	72
Aug-20	Average	326	138	49
	Max	441	222	54
Sep-20	Average	377	84	52
	Max	440	113	53

ANNEXURE-III
Ambient Air Quality Data- APR – 2020 to SEP – 2020
Month – Apr' 2020

SN	Location (Avg.24 Hrs.)	PM-10 ($\mu\text{g}/\text{m}^3$)	SO ₂ ($\mu\text{g}/\text{m}^3$)	NO ₂ ($\mu\text{g}/\text{m}^3$)	CO (mg/m^3)	PM-2.5 ($\mu\text{g}/\text{m}^3$)
1	Reservoir Area	32.3	12.5	21.3	1.4	9.7
2	Main Gate	44.9	5.6	15.0	0.8	29.7
3	Ash pond	21.2	14.6	19.4	1.8	12.3
4	Bhardesh Village	77.7	17.4	29.5	0.2	40.2
5	Ishrpura Village	76.0	15.3	24.9	0.3	37.8
6	Chuli Village	79.1	15.4	27.7	0.3	38.6

Month – May' 2020

SN	Location (Avg.24 Hrs.)	PM-10 ($\mu\text{g}/\text{m}^3$)	SO ₂ ($\mu\text{g}/\text{m}^3$)	NO ₂ ($\mu\text{g}/\text{m}^3$)	CO (mg/m^3)	PM-2.5 ($\mu\text{g}/\text{m}^3$)
1	Reservoir Area	32.1	18.2	20.8	1.0	9.7
2	Main Gate	45.8	5.7	15.6	1.2	30.3
3	Ash pond	22.6	17.2	18.7	1.5	18.6
4	Bhardesh Village	76.2	16.2	30.7	0.2	40.0
5	Ishrpura Village	78.1	13.6	25.8	0.3	38.3
6	Chuli Village	78.2	16.0	28.4	0.3	38.4

Month – Jun' 2020

SN	Location (Avg.24 Hrs.)	PM-10 ($\mu\text{g}/\text{m}^3$)	SO ₂ ($\mu\text{g}/\text{m}^3$)	NO ₂ ($\mu\text{g}/\text{m}^3$)	CO (mg/m^3)	PM-2.5 ($\mu\text{g}/\text{m}^3$)
1	Reservoir Area	32.0	19.0	24.0	1.3	9.7
2	Main Gate	51.0	6.0	16.0	1.6	32.0
3	Ash pond	24.0	19.0	20.0	1.7	15.0
4	Bhardesh Village	78.0	14.0	25.5	0.3	38.3
5	Ishrpura Village	76.4	13.6	25.8	0.3	38.3
6	Chuli Village	75.8	16.0	28.4	0.3	38.4

Month – Jul' 2020

SN	Location (Avg.24 Hrs.)	PM-10 ($\mu\text{g}/\text{m}^3$)	SO2 ($\mu\text{g}/\text{m}^3$)	NO2 ($\mu\text{g}/\text{m}^3$)	CO (mg/m^3)	PM-2.5 ($\mu\text{g}/\text{m}^3$)
1	Reservoir Area	31.0	13.0	21.0	1.9	8.8
2	Main Gate	44.0	5.0	16.0	1.9	30.0
3	Ash pond	22.0	20.0	21.0	1.5	14.0
4	Bhardesh Village	74.4	17.6	30.8	0.2	39.7
5	Ishrpura Village	75.5	13.6	25.8	0.3	38.3
6	Chuli Village	71.4	16.0	28.4	0.3	38.4

Month – Aug' 2020

SN	Location (Avg.24 Hrs.)	PM-10 ($\mu\text{g}/\text{m}^3$)	SO2 ($\mu\text{g}/\text{m}^3$)	NO2 ($\mu\text{g}/\text{m}^3$)	CO (mg/m^3)	PM-2.5 ($\mu\text{g}/\text{m}^3$)
1	Reservoir Area	29.0	21.0	13.0	1.6	8.7
2	Main Gate	43.0	N/W	5.0	1.5	27.0
3	Ash pond	22.0	18.0	14.0	1.7	12.0
4	Bhardesh Village	68.5	15.2	26.0	0.2	33.3
5	Ishrpura Village	71.3	14.4	26.3	0.3	33.6
6	Chuli Village	65.1	11.3	25.4	0.3	29.7

Month – Sep' 2020

SN	Location (Avg.24 Hrs.)	PM-10 ($\mu\text{g}/\text{m}^3$)	SO2 ($\mu\text{g}/\text{m}^3$)	NO2 ($\mu\text{g}/\text{m}^3$)	CO (mg/m^3)	PM-2.5 ($\mu\text{g}/\text{m}^3$)
1	Reservoir Area	31.0	27.0	13.0	0.8	8.7
2	Main Gate	44.0	N/W	5.0	0.9	25.0
3	Ash pond	21.0	21.0	7.0	1.7	12.0
4	Bhardesh Village	66.4	15.2	24.3	0.2	33.2
5	Ishrpura Village	66.4	14.0	25.6	0.3	31.6
6	Chuli Village	64.6	11.8	26.2	0.3	27.9

ANNEXURE-IV

Effluent Water Quality APR– 2020 to SEP– 2020

SN	Parameters	UoM	CPCB Limits	Results					
				April	May	June	July	Aug	Sept
1.	pH		6.5-8.5	6.85	6.85	6.98	6.83	7.10	7.25
2.	Biochemical Oxygen Demand (BOD) @ 27Deg C for 3 days	mg/L	< 30.0	25.00	22.63	21.73	21.80	22.10	22.78
3.	Chemical Oxygen Demand (COD)	mg/L	< 250	81.75	78.50	87.50	78.50	90.25	91.75
4.	Total Kjeldhal Nitrogen as NH3	mg/L	< 100	8.64	8.76	12.71	8.56	13.70	13.44
5.	Free Available Chlorine	mg/L	< 0.5	BDL<0.18	BDL<0.18	BDL<0.18	BDL<0.18	BDL<0.18	BDL<0.18
6.	Oil & Grease	mg/L	< 20	2.40	3.08	3.40	3.05	3.25	2.93
7.	Copper as Cu	mg/L	< 1	0.024	0.027	0.023	0.028	0.026	0.028
8.	Zinc as Zn	mg/L	< 1	0.31	0.32	0.32	0.36	0.39	0.40
9.	Iron as Fe	mg/L	< 1	0.42	0.45	0.51	0.48	0.59	0.57
10.	Total Suspended Solid	mg/L	< 100	39.75	43.50	45.25	43.75	48.25	48.50
11.	Ammonical Nitrogen as N	mg/L	< 50	4.89	5.19	5.46	5.21	5.65	5.48
12.	Nitrate Nitrogen	mg/L	< 10	2.29	2.48	2.62	2.43	2.73	2.59
13.	Total Chromium as Cr	mg/L	< 1	BDL<0.01	BDL<0.01	BDL<0.01	BDL<0.01	BDL<0.01	BDL<0.01



ARIHANT ANALYTICAL LABORATORY PVT. LTD.

AN ISO 9001:2015, ISO 14001:2004, OHSAS 18001:2007 CERTIFIED LABORATORY

272, Phase-IV, Sec-57, HSIIDC, Kundli, Sonapat-131028 (Haryana)

Ph. : 7082301442, 9250014551 Email : aalkundli@gmail.com

Website : www.aalkundli.com

TEST CERTIFICATE

Page 1 of 1

Issued To:	M/s Environze Global Limited 110, Laxmi Deep Tower, District Centre Laxmi Nagar, Delhi – 110 092	Report No.	AAL WQT-20200515003
Sample Description:	One Sample described as STP Outlet Water, was received.	Date of Receiving:	15/05/2020
Sample ID:	JSW Plant	Date of Starting:	15/05/2020
		Date of Completion:	20/05/2020
		Date of Reporting:	20/05/2020
		Sample Quantity:	1 Litre
		Sample Packing Condition:	Plastic Bottle
		Sample Submitted By:	Customer

TEST RESULT

S. No.	Test parameters	Unit	Results	Requirement as per CPCB Guideline		Testing Method
				Into Inland Surface Water	On land for Irrigation	
1	pH Value	-	6.87	5.5 - 9.0	5.5 - 9.0	IS 3025(P-11)-1983
2	Total Suspended Solids	mg/l	14.4	100 Max.	200 Max.	IS 3025(P-17)-1984
3	Oil & Grease	mg/l	<2.0	10 Max.	10 Max.	IS 3025(P-39)-1991
4	Biochemical Oxygen Demand (BOD - 3 days at 27°C)	mg/l	13.5	30 Max.	100 Max.	IS 3025(P-44)-1993
5	Chemical Oxygen Demand (COD)	mg/l	62.0	250 Max.	-	IS 3025(P-58)-2006
6	Total Nitrogen (as N)	mg/l	8.0	-	-	IS 3025(P-34)-1988
7	Ammonical Nitrogen (as N)	mg/l	<1.0	50 Max.	-	IS 3025(P-34)-1988
8	Faecal Coliform	MPN/100ml	34	<100	-	IS 1622-1981

****End of Report****

Vinay Dixit
(Microbiologist)

Ashutosh Srivastava
(SR. ANALYST)
Authorised Signatory

- Note:**
- The Result indicated above refer to the tested sample and listed test parameters only, endorsement of products is neither inferred nor implied.
 - Total liability of our laboratory is limited to the invoice amount.
 - This report shall not be reproduced wholly or in part without written consent of the laboratory.
 - This report shall not be used in any advertising media or as evidence in the court of law without prior written consent of the laboratory.
 - The non-perishable sample received shall be destroyed after one month and perishable sample shall be destroyed after one week from the date of issue of report unless specified.



ARIHANT ANALYTICAL LABORATORY PVT. LTD.

AN ISO 9001:2015, ISO 14001:2004, OHSAS 18001:2007 CERTIFIED LABORATORY

272, Phase-IV, Sec-57, HSII DC, Kundli, Sonapat-131028 (Haryana)

Ph. : 7082301442, 9250014551 Email : aalkundli@gmail.com

Website : www.aalkundli.com

TEST CERTIFICATE

Page 1 of 1

Issued To: M/s Environze Global Limited
110, Laxmi Deep Tower,
District Centre Laxmi Nagar,
Delhi - 110 092

Sample Description: One Sample described as STP Outlet Water,
was received.

Sample ID: JSW Plant

Report No. AAL WQT-20200612025

Date of Receiving: 12/06/2020
Date of Starting: 12/06/2020
Date of Completion: 17/06/2020
Date of Reporting: 17/06/2020
Sample Quantity: 1 Litre
Sample Packing Condition: Plastic Bottle
Sample Submitted By: Customer

TEST RESULT

S. No.	Test parameters	Unit	Results	Requirement as per CPCB Guideline		Testing Method
				Into Inland Surface Water	On land for Irrigation	
1	pH Value	-	7.31	5.5 - 9.0	5.5 - 9.0	IS 3025(P-11)-1983
2	Total Suspended Solids	mg/l	16.0	100 Max.	200 Max.	IS 3025(P-17)-1984
3	Oil & Grease	mg/l	<2.0	10 Max.	10 Max.	IS 3025(P-39)-1991
4	Biochemical Oxygen Demand (BOD - 3 days at 27°C)	mg/l	14.5	30 Max.	100 Max.	IS 3025(P-44)-1993
5	Chemical Oxygen Demand (COD)	mg/l	70.0	250 Max.	-	IS 3025(P-58)-2006
6	Total Nitrogen (as N)	mg/l	10.4	-	-	IS 3025(P-34)-1988
7	Ammonical Nitrogen (as N)	mg/l	1.6	50 Max.	-	IS 3025(P-34)-1988
8	Faecal Coliform	MPN/100ml	30	<100	-	IS 1622-1981

End of Report

Vinay Dixit
(Microbiologist)

Ashutosh Srivastava
Ashutosh Srivastava
(SR. ANALYST)
Authorised Signatory

Note: 1. The Result indicated above refer to the tested sample and listed test parameters only, endorsement of products is neither inferred nor implied.
2. Total liability of our laboratory is limited to the invoice amount.
3. This report shall not be reproduced wholly or in part without written consent of the laboratory.
4. This report shall not be used in any advertising media or as evidence in the court of law without prior written consent of the laboratory.
5. The non-perishable sample received shall be destroyed after one month and perishable sample shall be destroyed after one week from the date of issue of report unless specified.



ARIHANT ANALYTICAL LABORATORY PVT. LTD.

AN ISO 9001:2015, ISO 14001:2004, OHSAS 18001:2007 CERTIFIED LABORATORY

272, Phase-IV, Sec-57, HSIIDC, Kundli, Sonapat-131028 (Haryana)

Ph. : 7082301442, 9250014551 Email : aalkundli@gmail.com

Website : www.aalkundli.com

TEST CERTIFICATE

Page 1 of 1

Issued To:	M/s Enytronze Global Limited 110, Laxmi Deep Tower, District Centre Laxmi Nagar, Delhi - 110 092	Report No.	AAL WQT-20200713007
Sample Description:	One Sample described as STP Outlet Water, was received.	Date of Receiving:	13/07/2020
Sample ID:	JSW Plant	Date of Starting:	13/07/2020
		Date of Completion:	18/07/2020
		Date of Reporting:	18/07/2020
		Sample Quantity:	1 Litre
		Sample Packing Condition:	Plastic Bottle
		Sample Submitted By:	Customer

TEST RESULT

S. No.	Test parameters	Unit	Results	Requirement as per CPCB Guideline		Testing Method
				Into Inland Surface Water	On land for Irrigation	
1	pH Value		7.42	5.5 - 9.0	5.5 - 9.0	IS 3025(P-11)-1983
2	Total Suspended Solids	mg/l	19.3	100 Max.	200 Max.	IS 3025(P-17)-1984
3	Oil & Grease	mg/l	<2.0	10 Max.	10 Max.	IS 3025(P-39)-1991
4	Biochemical Oxygen Demand (BOD - 3 days at 27°C)	mg/l	17.0	30 Max.	100 Max.	IS 3025(P-44)-1993
5	Chemical Oxygen Demand (COD)	mg/l	89.0	250 Max.	-	IS 3025(P-58)-2006
6	Total Nitrogen (as N)	mg/l	11.5	-	-	IS 3025(P-34)-1988
7	Ammonical Nitrogen (as N)	mg/l	2.6	50 Max.	-	IS 3025(P-34)-1988
8	Faecal Coliform	MPN/100ml	40	<100	-	IS 1622-1981

End of Report

Vinay Dixit
(Microbiologist)

Ashutosh Srivastava
(SR. ANALYST)
Authorised Signatory

Note:

1. The Result Indicated above refer to the tested sample and listed test parameters only, endorsement of products is neither inferred nor implied.
2. Total liability of our laboratory is limited to the invoice amount.
3. This report shall not be reproduced wholly or in part without written consent of the laboratory.
4. This report shall not be used in any advertising media or as evidence in the court of law without prior written consent of the laboratory.
5. The non-perishable sample received shall be destroyed after one month and perishable sample shall be destroyed after one week from the date of issue of report unless specified.



ARIHANT ANALYTICAL LABORATORY PVT. LTD.

AN ISO 9001:2015, ISO 14001:2004, OHSAS 18001:2007 CERTIFIED LABORATORY

272, Phase-IV, Sec-57, HSIIDC, Kundli, Sonapat-131028 (Haryana)

Ph. : 7082301442, 9250014551 Email : aalkundli@gmail.com

Website : www.aalkundli.com

TEST CERTIFICATE

Page 1 of 1

Issued To:	M/s Envirozone Global Limited 110, Laxmi Deep Tower, District Centre Laxmi Nagar, Delhi – 110 092	Report No.	AAL WQT-20200817003
Sample Description:	One Sample described as STP Outlet Water, was received.	Date of Receiving:	17/08/2020
Sample ID:	JSW Plant	Date of Starting:	17/08/2020
		Date of Completion:	22/08/2020
		Date of Reporting:	22/08/2020
		Sample Quantity:	1 Litre
		Sample Packing Condition:	Plastic Bottle
		Sample Submitted By:	Customer

TEST RESULT

S. No.	Test parameters	Unit	Results	Requirement as per CPCB Guideline		Testing Method
				Into Inland Surface Water 5.5 - 9.0	On land for Irrigation 5.5 - 9.0	
1	pH Value	-	7.38			IS 3025(P-11)-1983
2	Total Suspended Solids	mg/l	23.4	100 Max.	200 Max.	IS 3025(P-17)-1984
3	Oil & Grease	mg/l	<2.0	10 Max.	10 Max.	IS 3025(P-39)-1991
4	Biochemical Oxygen Demand (BOD - 3 days at 27°C)	mg/l	19.0	30 Max.	100 Max.	IS 3025(P-44)-1993
5	Chemical Oxygen Demand (COD)	mg/l	97.0	250 Max.	-	IS 3025(P-58)-2006
6	Total Nitrogen (as N)	mg/l	12.4	-	-	IS 3025(P-34)-1988
7	Ammonical Nitrogen (as N)	mg/l	3.2	50 Max.	-	IS 3025(P-34)-1988
8	Faecal Coliform	MPN/100ml	38	<100		IS 1622-1981

End of Report


Ashutosh Srivastava
 (SR. ANALYST)
 Authorised Signatory

Note: 1. The Result Indicated above refer to the tested sample and listed test parameters only, endorsement of products is neither inferred nor implied.
 2. Total liability of our laboratory is limited to the invoice amount.
 3. This report shall not be reproduced wholly or in part without written consent of the laboratory.
 4. This report shall not be used in any advertising media or as evidence in the court of law without prior written consent of the laboratory.
 5. The non-perishable sample received shall be destroyed after one month and perishable sample shall be destroyed after one week from the date of issue of report unless specified.



ARIHANT ANALYTICAL LABORATORY PVT. LTD.

AN ISO 9001:2015, ISO 14001:2004, OHSAS 18001:2007 CERTIFIED LABORATORY

272, Phase-IV, Sec-57, HSIIDC, Kundli, Sonapat-131028 (Haryana)

Ph. : 7082301442, 9250014551 Email : aalkundli@gmail.com

Website : www.aalkundli.com

TEST CERTIFICATE

Page 1 of 1

Issued To: M/s Environze Global Limited
110, Laxmi Deep Tower,
District Centre Laxmi Nagar,
Delhi – 110 092

Sample Description: One Sample described as STP Outlet Water,
was received.

Sample ID: JSW Plant

Report No. AAL WQT-20200909020

Date of Receiving: 09/09/2020

Date of Starting: 09/09/2020

Date of Completion: 14/09/2020

Date of Reporting: 14/09/2020

Sample Quantity: 1 Litre

Sample Packing Condition: Plastic Bottle

Sample Submitted By: Customer

TEST RESULT

S. No.	Test parameters	Unit	Results	Requirement as per CPCB Guideline		Testing Method
				Into Inland Surface Water	On land for Irrigation	
1	pH Value	-	7.46	5.5 - 9.0	5.5 - 9.0	IS 3025(P-11)-1983
2	Total Suspended Solids	mg/l	23.6	100 Max.	200 Max.	IS 3025(P-17)-1984
3	Oil & Grease	mg/l	<2.0	10 Max.	10 Max.	IS 3025(P-39)-1991
4	Biochemical Oxygen Demand (BOD - 3 days at 27°C)	mg/l	20.5	30 Max.	100 Max.	IS 3025(P-44)-1993
5	Chemical Oxygen Demand (COD)	mg/l	102.0	250 Max.	-	IS 3025(P-58)-2006
6	Total Nitrogen (as N)	mg/l	14.5	-	-	IS 3025(P-34)-1988
7	Ammonical Nitrogen (as N)	mg/l	4.2	50 Max.	-	IS 3025(P-34)-1988
8	Faecal Coliform	MPN/100ml	34	<100		IS 1622-1981

End of Report

Vinita Dixit
(Microbiologist)

Ashutosh Srivastava
(SR. ANALYST)
Authorised Signatory

- Note:**
- The Result indicated above refer to the tested sample and listed test parameters only, endorsement of products is neither inferred nor implied.
 - Total liability of our laboratory is limited to the invoice amount.
 - This report shall not be reproduced wholly or in part without written consent of the laboratory.
 - This report shall not be used in any advertising media or as evidence in the court of law without prior written consent of the laboratory.
 - The non-perishable sample received shall be destroyed after one month and perishable sample shall be destroyed after one week from the date of issue of report unless specified.

Ref: JSWE(B)/ENV/20-21/015

Date: 25.06.2020

To,
The Member Secretary
Rajasthan State Pollution Control Board
4-Institutional Area, Jhalana Doongari,
Jaipur – 302004

Sub: Compliance Report – Consent to Operate Environmental Clearance for 1080 MW Lignite based Power Plant at Village-Bhadresh, District Barmer.

Ref: Consent to Operate

1. Compliance to CTO for Unit 1 & 2, File No. **F(HDF)/Barmer(Barmer)/9(1)/2016-2017/28-30 Order No. 2020-2021/CPM/5618, Dt: 27/04/2020.**
2. Compliance to CTO for Unit 3 & 4, File No. **F(HDF)/Barmer(Barmer)/9(1)/2016-2017/31-33 Order No: 2020-2021/CPM/5619, Dated: 27/04/2020.**
3. Compliance to CTO for Unit 5 & 6, File No. **F(HDF)/Barmer(Barmer)/12(1)/2017-2018/1505-1507; Order No. 2017-2018/HDF/2564, Dt: 30/05/2017.**
4. Compliance to CTO for Unit 7 & 8, File No. **F(HDF)/Barmer(Barmer)/12(1)/2017-2018/1502-1504; Order No. 2017-2018/HDF/2563, Dt: 30/05/2017.**

Dear Sir,

With reference to Consent To Operate issued for Unit # 1-2, 3-4, 5-6 and 7-8 for operating 1080 MW (8 x 135 MW) Lignite Based Thermal Plant of M/s JSW ENERGY (BARMER) Ltd), Dist-Barmer, Rajasthan, we herewith submit half-yearly compliance report, for the period pertaining to **OCTOBER – 2019 to MARCH – 2020**, for the conditions stipulated in the Environmental clearance issued for this Power Project. Analysis Data has uploaded on JSWEBL website - <http://www.jsw.in/energy/about-barmer-plant>.

We have taken up the Operation activity at the Power Plant as per the conditions stipulated in this Consent to Operate.

Thanking you,

For JSW ENERGY (BARMER) Ltd.



Vinod Jindal
AGM (Operation, Environment & Chemistry)

Enclosure:

1. Compliance Report
2. Stack monitoring Data
3. AAQ Monitoring Data
4. Effluent Water Data
5. STP Treated Water Quality



C.C. The Regional Officer – RSPCB, Balotra.